



Sample ID	Sample Location Description	Fixture Type	Sample Type	Concentration
WL-05A	Room 221 - Mrs. Fraebe	S - Sink	First Draw	147 ppb
WL-06A	Room 220 - Mrs. Spragg	S - Sink	First Draw	26.2 ppb
WL-07A	Room 219 - Lopian	S - Sink	First Draw	22.7 ppb
WL-08A	Room 218 - Mrs. Hoagland	S - Sink	First Draw	24.0 ppb
WL-09A	Outside Room 216 - outside	DF - Drinking Fountain	First Draw	8.89 ppb

MS. FITZ

Table 1.2 - Results over 5.00 ppb

Refer to Appendix B for a sample notification letter for results exceeding 5 ppb.

- The sample results as identified below in Table 1.2 exceed 5.00 ppb. Provide individual written or electronic notification to parents and legal guardians of all enrolled students the sample results in Table 1.2. Include in the notification the location and source exceeding 5 ppb, and the USEPA website for information about lead in drinking water: www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water.
- Provide to parents and legal guardians all sample results as shown in Table 1.1. This can be done, at a minimum, on the school's website.
- Submit to IDPH at dph.leadh2o@illinois.gov all sample results as shown in Table 1.1. As a courtesy, this step has been done by IDEAL. Please refer to Appendix A for electronic transmittal(s).

Based on sample results, the following are notification requirements for this building:

Notification Requirements:

The Illinois Department of Public Health (IDPH) must be informed of the results. The LEA is also required to provide notification of all water testing results to parents and legal guardians of all enrolled students. Notification can be done, at a minimum, on the school's website. In addition, when any test result exceeds 5 ppb, individual written or electronic notification is required to be sent to parents and legal guardians of all enrolled students and must include the location and source exceeding 5 ppb, and the USEPA website for information about lead in drinking water: www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water.

This building is subject to the Act. Notification as outlined below is not optional.

Notifications