

Lead Testing in Drinking Water West Lincoln-Broadwell Elementary School

Summary of Sampling

28 water samples were collected from 14 sources. All results are shown in Table 1.1.

Table 1.1

Sample ID	Sample Location Description	Fixture Type	Sample Type	Concentration
WL-01A	Kitchen Prep Sink - Right	KS - Kitchen Sink	First Draw	4.90 ppb
WL-01B	Kitchen Prep Sink - Right	KS - Kitchen Sink	Flush	ND
WL-02A	Kitchen Prep Sink - Middle	KS - Kitchen Sink	First Draw	2.24 ppb
WL-02B	Kitchen Prep Sink - Middle	KS - Kitchen Sink	Flush	ND
WL-03A	Kitchen Prep Sink - Left	KS - Kitchen Sink	First Draw	2.39 ppb
WL-03B	Kitchen Prep Sink - Left	KS - Kitchen Sink	Flush	ND
WL-04A	Outside Boiler Room	DF - Drinking Fountain	First Draw	ND
WL-04B	Outside Boiler Room	DF - Drinking Fountain	Flush	ND
WL-05A	Room 221	S - Sink	First Draw	147 ppb
WL-05B	Room 221	S - Sink	Flush	2.41 ppb
WL-06A	Room 220	S - Sink	First Draw	26.2 ppb
WL-06B	Room 220	S - Sink	Flush	ND
WL-07A	Room 219	S - Sink	First Draw	22.7 ppb
WL-07B	Room 219	S - Sink	Flush	2.09 ppb
WL-08A	Room 218	S - Sink	First Draw	24.0 ppb
WL-08B	Room 218	S - Sink	Flush	ND
WL-09A	Outside Room 216	DF - Drinking Fountain	First Draw	8.89 ppb
WL-09B	Outside Room 216	DF - Drinking Fountain	Flush	ND
WL-10A	Northwest of Gym	DF - Drinking Fountain	First Draw	ND
WL-10B	Northwest of Gym	DF - Drinking Fountain	Flush	ND
WL-11A	Outside Teachers' Lounge - Upper	DF - Drinking Fountain	First Draw	ND
WL-11B	Outside Teachers' Lounge - Upper	DF - Drinking Fountain	Flush	ND
WL-12A	Outside Teachers' Lounge - Lower	DF - Drinking Fountain	First Draw	ND
WL-12B	Outside Teachers' Lounge - Lower	DF - Drinking Fountain	Flush	ND
WL-13A	Room 228 - Science	S - Sink	First Draw	ND
WL-13B	Room 228 - Science	S - Sink	Flush	ND
WL-14A	Room 205 - PE Coach Office	S - Sink	First Draw	4.18 ppb
WL-14B	Room 205 - PE Coach Office	S - Sink	Flush	ND

ND = None Detected